

CWS Practice Test Questions and Answers

1. What does CWS typically stand for in water treatment contexts?

- A) Community Water Supply
- B) Certified Water Specialist
- C) Clean Water Standards
- D) Central Water Storage

2. What is the primary purpose of chlorination in water treatment?

- A) To improve taste only
- B) To disinfect water by killing bacteria, viruses, and other pathogens
- C) To add minerals to water
- D) To increase water pressure

3. Which water quality parameter measures the total dissolved solids in water?

- A) pH level
- B) TDS (Total Dissolved Solids)
- C) Turbidity
- D) Alkalinity

4. What is the EPA maximum contaminant level (MCL) for lead in drinking water?

- A) 5 ppb
- B) 15 ppb (parts per billion)
- C) 25 ppb
- D) 50 ppb

Answers: 1-B 2-B 3-B 4-B

For More CWS Questions and Answers FREE, CWS Online Prep Training, CWS Exam, CWS Study Guide, CWS Flashcards, CWS Quizzes visit:

CWS Practice Test