

# NEC Practice Test Questions and Answers

**1. According to the National Electrical Code (NEC), what is the minimum working space clearance in front of electrical equipment rated 600 volts or less?**

- A) 2 feet
- B) 3 feet
- C) 4 feet
- D) 6 feet

**2. What is the maximum allowed voltage drop for branch circuits according to NEC recommendations?**

- A) 3%
- B) 5%
- C) 8%
- D) 10%

**3. Which NEC article covers the installation of ground-fault circuit interrupters (GFCIs)?**

- A) Article 210
- B) Article 250
- C) Article 300
- D) Article 410

**4. What is the required ampacity for a 20-amp branch circuit conductor according to the NEC?**

- A) 15 amperes
- B) 20 amperes
- C) 25 amperes
- D) 30 amperes

Answers: 1-B 2-B 3-A 4-B

For More NEC Questions and Answers FREE, NEC Online Prep Training, NEC Exam, NEC Study Guide, NEC Flashcards, NEC Quizzes visit:

## NEC Practice Test